



Backup Power Status Summary

| Sewer System | Backup Power? | Notes |
|--------------|---------------|--|
| WWTP | Y | Permanent generator |
| LS A | Y | Permanent generator |
| LS A1 | Y | Permanent generator |
| LS B | Y | Permanent generator |
| LS B1 | Y | Dedicated portable generator (stored onsite) |
| LS B2 | Y | Dedicated portable generator (stored offsite) |
| LS B3 | Y | Permanent generator |
| LS B4 | Y | Permanent generator |
| LS 4 | Y** | **Portable generator shared between 4 & 8 (stored offsite) |
| LS 8 | Y** | **Portable generator shared between 4 & 8 (stored offsite) |
| LS 9 | Y | Permanent |

| Water System | Backup Power? | Notes |
|-----------------------|---------------|--|
| Well SS1 | N | *Powered by generator at SS2 |
| Well SS2 | N | *Generator failed; Produces 25% of req'd power |
| Well SS3 | N | |
| Well SR3 | N | |
| Well SR4 | Y | Temporary portable generator installed 7/18/2019 |
| Liemert Booster | Y | Permanent generator |
| Stuart St Booster | Y | Permanent generator |
| Rodeo Grounds Booster | Y | Permanent generator |

| Other | Backup Power? | Notes |
|--------------|---------------|---|
| Admin Office | Y | Dedicated portable generator (stored offsite) |
| Fire | Y | Permanent generator |